




### Product Description

The smart motorstarter UG 9410 can be used for softstart, softstop, reversing and protecting 3 phase asynchronous motors. By measuring the line current a thermal model is used to calculate the motor temperature, and in the case of overtemperature the motor is disconnected. In addition also a thermo switch can be used. The reversing is done via relays. The relays are switched without current flow, this provides long service life.

### Function Diagram



### Your Advantages

- Widely used measuring and automation protocol
- Up to 7 functions in one device
  - Reversing anticlockwise,
  - Reversing clockwise
  - Softstart
  - Softstop
  - Motor protection
  - Phase sequence monitoring
  - Phase failure monitoring
- 80 % less space
- Simple and time-saving commissioning as well as user-friendly
- Operation through parameterization via modbus
- Hybrid relay combines benefits of relay technology with non-wearing semiconductor technology
- High availability by
  - Temperature monitoring of semiconductors
  - High withstand voltage up to 1500 V
  - Load free relay reversing function
  - Device overload
- Pluggable clamps
- TWIN- connection terminals to loop auxiliary supply and Bus

### Features

- According to IEC/EN 60947-4-2
- Modbus RTU-interface
- To reverse 3 phase motors up to 0.18 kW ... 2.2 kW at 400 V
- 2-phase softstart, softstop
- 3 potentiometer for setting the modbus adress and baud rate
- 5 LEDs for status indication
- Reversing with relays without current, softstart, softstop with thyristor
- Galvanic separation between control circuit and power circuit
- Width: 22.5 mm


### Approvals and Markings



### Applications

- Reversing operation for door and gate controls, bridge drives and lifting applications
- Conveyor systems
- Actuating drives in process controls

### Circuit Diagram



| Connection Terminals |                             |
|----------------------|-----------------------------|
| Terminal designation | Signal description          |
| A1 (+)               | Auxiliary voltage + DC 24 V |
| A2                   | Auxiliary voltage 0 V       |
| A                    | Modbus signal A             |
| B                    | Modbus signal B             |
| L1                   | Phase voltage L1            |
| L2                   | Phase voltage L2            |
| L3                   | Phase voltage L3            |
| T1                   | Motor connection T1         |
| T2                   | Motor connection T2         |
| T3                   | Motor connection T3         |

## Function

### Softstart

2 motor phases are controlled using thyristors, so that the motor current rises continuously. The starting torque behaves in the same way. This provides shock free starting and reduces mechanical failures. Starting time and starting voltage can be adjusted via Modbus.

### Softstop

2 motor phases are controlled using thyristors, so that the motor current drops continuously. The motor torque behaves in the same way on run down. This provides shock free stopping and reduces mechanical failures. Stopping time and stopping voltage can be adjusted via Modbus.

### Motor protection

The thermal load of the motor is calculated using a thermal model. The current is measured in phase T3. A symmetric current load of all 3 phases of the motor is assumed for flawless functioning. When the trigger value – stored in the trigger characteristics-, is reached, the motor is switched off and the device switches to fault 8.

The fault and motor leading can be acknowledged via Modbus.

**Attention:** The data of the thermal model is cleared through reset. In this case, the user must provide adequate cooling time of the motor resp. of the UG 9410.

### Phase sequence detection

For correct function of the unit a clockwise phase sequence is required. The phase sequence monitoring feature checks on power up the sequence of the connected voltage and signals on anticlockwise sequence the fault 3. This fault can be cleared via Modbus.

### Phase failure monitoring

After connecting the auxiliary supply, the unit checks if all 3 phases are correct. If one or more phases are missing, the unit indicates fault 4. This fault can be reset via Modbus.

## Indicators

Green LED "On": Permanent on - Supply connected

Red LED "ERR": Flashing - Failure code of the device

Yellow LED "Bus": Flashing - When receiving or transmitting Modbus data

Yellow LED "L": Permanent on - Motor turns anti-clockwise  
Flashing - Softstart or softstop active on anti-clockwise turn

Yellow LED "R": Permanent on - Motor turns clockwise  
Flashing - Softstart or softstop active on clockwise turn

- Failure code :
- 1 - Overtemperature on semiconductors
  - 2 - Wrong mains frequency
  - 3 - Phase reversal detected
  - 4 - Phase failure detected
  - 7 - Incorrect temperature measurement circuit
  - 8 - Motor protection has responded
  - 9 - Modbus communication failure
  - 10 - Checksum failure EEPROM

1\*) - 10\*) = Number of flashing pulses in sequence


## Reset Function

By sending a reset command a reset can be operated via Modbus

## Modbus RTU

For communication between motor controller and a supervising control the Modbus RTU protocol according to Specification V 1.1b3 is used.

## Setting




M11731\_a

| Position      | 1       | 2       | 3       | 4       | 5      | 6      | 7      | 8      |
|---------------|---------|---------|---------|---------|--------|--------|--------|--------|
| Potentiometer |         |         |         |         |        |        |        |        |
| BAUD          |         |         |         |         |        |        |        |        |
| Baud rate     | 1200    | 2400    | 4800    | 9600    | 19200  | 38400  | 57600  | 115200 |
| Response Time | < 50 ms | < 25 ms | < 12 ms | < 10 ms | < 5 ms | < 5 ms | < 5 ms | < 5 ms |


| Technical Data                         |  |
|--|--|
| <b>Nominal voltage L1/L2/L3:</b>       | 3 AC 200 ... 480 V $\pm 10\%$          |
| <b>Nominal frequency:</b>              | 50 / 60 Hz , automatic detection       |
| <b>Auxiliary voltage:</b>              | DC 24 V $\pm 10\%$                     |
| <b>Motor power:</b>                    | 0.5 A ... 5.0 A adjustable via Modbus  |
| <b>Operating mode</b>                  |  |
| 5.0 A:                                 | AC 53a: 6-2: 100-30 IEC/EN 60947-4-2   |
| <b>Surge current:</b>                  | 200 A ( $t_p = 20$ ms )                |
| <b>Load limit integral:</b>            | 200 A <sup>2</sup> s ( $t_p = 10$ ms ) |
| <b>Peak reverse voltage:</b>           | 1500 V                                 |
| <b>Overvoltage limiting:</b>           | AC 510 V                               |
| <b>Leakage current in off state:</b>   | $< 3 \times 0.5$ mA                    |
| <b>Start / deceleration voltage:</b>   | 30 ... 80 % adjustable via Modbus      |
| <b>Start / deceleration ramp:</b>      | 0 ... 10 s adjustable via Modbus       |
| <b>Consumption:</b>                    | 2 W                                    |
| <b>Switchover delay time:</b>          | 150 ms                                 |
| <b>Start up delay for master tick:</b> | Min. 25 ms                             |
| <b>Release delay for master tick:</b>  | Min. 30 ms                             |
| <b>Current measurement:</b>            | AC 0.5 ... 30 A                        |
| Measuring accuracy:                    | $\pm 5\%$ of end of scale value        |
| <b>Measured value update time</b>      |  |
| At 50 Hz:                              | 100 ms                                 |
| At 60 Hz:                              | 83 ms                                  |
| <b>Motor protection</b>                |  |
| Up to 5.0 A:                           | Class 10                               |
| Electronically, with thermal memory    |  |
| Reset:                                 | Manual via Modbus                      |
| <b>Short circuit strength</b>          |  |
| <b>max. fuse rating:</b>               | 25 A gG / gL IEC/EN 60947-5-1          |
| General Data                           |  |

|  |  |                  |
|--|--|------------------|
| <b>Operating mode:</b>                   | Continuous operation                           |                  |
| Operation:                               | 0 ... + 65 °C (see derating curve)             |                  |
| Storage:                                 | - 40 ... + 70 °C                               |                  |
| <b>Relative air humidity:</b>            | 93 % at 40 °C                                  |                  |
| <b>Altitude:</b>                         | < 1000 m                                       |                  |
| <b>Clearance and creepage distances</b>  |  |                  |
| Rated impuls voltage / pollution degree  |  |                  |
| Motor voltage- control voltage:          | 6 kV / 2                                       | IEC 60664-1      |
| Motor voltage- Modbus:                   | 6 kV / 2                                       | IEC 60664-1      |
| Overvoltage category:                    | III  |                  |
| <b>EMC</b>                               |  |                  |
| Electrostatic discharge:                 | 8 kV (air)                                     | IEC/EN 61000-4-2 |
| HF-irradiation                           |  |                  |
| 80 MHz ... 1.0 GHz:                      | 10 V / m                                       | IEC/EN 61000-4-3 |
| 1.0 GHz ... 2.5 GHz:                     | 3 V / m  | IEC/EN 61000-4-3 |
| 2.5 GHz ... 2.7 GHz:                     | 1 V / m  | IEC/EN 61000-4-3 |
| Fast transients:                         | 2 kV   | IEC/EN 61000-4-4 |
| Surge voltages between                   |  |                  |
| Wires for power supply:                  | 1 kV   | IEC/EN 61000-4-5 |
| Between wire and ground:                 | 2 kV   | IEC/EN 61000-4-5 |
| HF wire guided:                          | 10 V   | IEC/EN 61000-4-6 |
| Voltage dips                             | IEC/EN 61000-4-11                              |                  |
| <b>Interference emission</b>             |  |                  |
| Wire guided:                             | Limit value class B                            | IEC/EN 60947-4-2 |
| Radio irradiation:                       | Limit value class B                            | IEC/EN 60947-4-2 |
| Harmonics:                               | EN 61000-3-2                                   |                  |
| <b>Degree of protection:</b>             |  |                  |
| Housing:                                 | IP 40  | IEC/EN 60529     |
| Terminals:                               | IP 20  | IEC/EN 60529     |
| <b>Vibration resistance:</b>             | Amplitude 0,35 mm                              |                  |
|  | Frequency 10 ... 55 Hz, IEC/EN 60068-2-6       |                  |
| <b>Climate resistance:</b>               | 0 / 065 / 04 IEC/EN 60068-1                    |                  |
| <b>Wire connection:</b>                  | DIN 46228-1/-2/-3/-4                           |                  |
| <b>Removable terminal blocks</b>         |  |                  |
| <b>Wire connection</b>                   |  |                  |
| Phase voltage and motor                  |  |                  |
| pluggable screw terminal (S):            | 0.25 ... 2.5 mm <sup>2</sup> solid or          |                  |
|  | 0.25 ... 2.5 mm <sup>2</sup> stranded ferruled |                  |
| <b>Wire connection:</b>                  |  |                  |
| Bus and auxiliary supply                 |  |                  |
| pluggable Twin-cage-clamp-terminal (PT): | 0.25 ... 1.5 mm <sup>2</sup> solid or          |                  |
|  | 0.25 ... 1.5 mm <sup>2</sup> stranded ferruled |                  |
| Insulation of wires or                   |  |                  |
| sleeve length:                           | 8 mm   |                  |
| <b>Fixing torque:</b>                    | 0.5 ... 0.6 Nm                                 |                  |

| Technical Data                              |                       |              |
|---|-----------------------|--------------|
| Mounting:                                   | DIN rail              | IEC/EN 60715 |
| Weight:                                     | 220 g                 |              |
| Dimensions                                  |                       |              |
| Width x height x depth:                     | 22.5 x 105 x 120.3 mm |              |
| Standard Type                               |                       |              |
| UG 9410PM 3 AC 200 ... 480 V 50/60 Hz 5.0 A |                       |              |
| Article number:                             | 0067521               |              |
| • Nominal voltage:                          | 3 AC 200 ... 480 V    |              |
| • Nominal motor current:                    | 5.0 A                 |              |
| • Modbus RTU                                |                       |              |
| • Adjustable baud rate                      |                       |              |
| • Width:                                    | 22.5 mm               |              |



**Derating curve:**  
Rated continuous current depending on ambient temperature and distance  
Enclosure without ventilation slots



Trigger characteristics  
Motor overload protection

## Setting Facilities

- Potentiometer ADR10: - Unit adress x 10
- Potentiometer ADR1: - Unit adress x 1
- Potentiometer BAUD: - Baud rate

The module address and baud rate is only read after connecting the auxiliary supply!

## Group fusing

Several motor starters can be wired in parallel on the supply side. Please make sure, that the total current cannot exceed 16 A. If several starters are use together and require more than 16 A, groups have to be split up for max 16 A.

## Set-up Procedure

1. Connect motor and device according to application example. The 3 phases must be connected in correct sequence, wrong phase sequence will lead to failure (see failure code)
2. Setting unit adress and baud rate via potentiometer.
3. Power up the unit.
4. Parametrization via Modbus
5. At correct setting, the motor should ramp up continuously to full speed.

## Safety Notes


- Never clear a fault when the device is switched on

**Attention:** This device can be started directly on the phase voltage without a contactor. Please be aware that the motor is still connected to the supply voltage also when it is not running. Therefore for work on motor and controller the supply has to be disconnected via E-stop.



- The user must ensure that the device and the necessary component are mounted and connected according to the locally applicable regulations and technical standards (VDE, TÜV,BG).
- Adjustments may only be carried out by qualified specialist staff and the applicable safety rules must be observed.
- Touch proof security is only provided when the power connection terminals are plugged into the unit.

## Application Example



Motor control with UG 9410 and PLC via Modbus

## Bus Interface

|           |  |
|-----------|--|
| Protocol  | Modbus Seriell RTU                                       |
| Adress    | 1 to 99  |
| Baud rate | 1200, 2400, 4800, 9600, 19200, 38400, 57600, 115200 Baud |
| Data bit  | 8  |
| Stop bit  | 2  |
| Parity    | None   |

More information about the interface, wiring rules, device identification and communication monitoring can be found in the Modbus user manual.

## Function-Codes

At UG 9410 the following function codes are implemented:

| Function-Code | Name                    | Description                         |
|---------------|-------------------------|-------------------------------------|
| 0x03          | Read Holding Register   | Device parameter read word by word  |
| 0x04          | Read Input Register     | Actual values read word by word     |
| 0x05          | Write Single Coil       | Outputs write individually          |
| 0x06          | Write Single Register   | Device parameter write word by word |
| 0x10          | Write Multiple Register | Device parameter write in blocks    |

## Device configuration

If required the device configuration data can be saved permanently by setting the the Bit "Write configuration to EEPROM". The data is copied from the EEPROM to the relevant register when connecting the auxiliary voltage. As the numbers of write cycles of an EEPROM are limited, the writing must not be done in cycles. In addition it is not possible to receive modbus telegrams during a period of 50 ms while writing the EEPROM.

## Parameter table

Every slave owns an output- configuration- and actual value table. In these tables it is defined under which address the parameters can be found.

Single Coils (Control signals):

| Register-Address | Protocol-Adresse | Name                          | Value range      | Description                                   | Data type | Access rights |
|------------------|------------------|-------------------------------|------------------|---|-----------|---------------|
| 1                | 0                | RunRight                      | 0x0000<br>0xFF00 | Motor turns right off<br>Motor turns right on | BIT       | write         |
| 2                | 1                | RunLeft                       | 0x0000<br>0xFF00 | Motor turns left off<br>Motor turns left on   | BIT       | write         |
| 3                | 2                | Reset                         | 0x0000<br>0xFF00 | No function<br>Device reset                   | BIT       | write         |
| 4                | 3                | Write configuration to EEPROM | 0x0000<br>0xFF00 | No function<br>Save parameter                 | BIT       | write         |

Input Register (Device state and measuring values):

| Register-Address | Protocol-Adresse | Name                            | Value range | Description   | Data type | Access rights |
|------------------|------------------|---------------------------------|-------------|---|-----------|---------------|
| 30001            | 0                | State word 1<br>Device failure  | 0 ... 10    | 0: No failure<br>1: Overtemperature LT<br>2: Wrong frequency<br>3: Phase reversal<br>4: Phase failure<br>5:<br>6:<br>7: Temperatur circuit fault<br>8: Motor protection device actuated<br>9: Communication fault Modbus<br>10: Checksum failure EEPROM | UINT16    | reading       |
| 30002            | 1                | State word 2<br>State of device | 0 ... 6     | 0: Device initialize<br>1: Wait for start<br>2: Softstart ramp<br>3: Clockwise On<br>4: Anti-clockwise On<br>5: Softstop ramp<br>6: Device in errormode   | UINT16    | reading       |
| 30003            | 2                | Actual motor current            | 0 ... 3000  | Actual motor current in 1/100 A   | UINT16    | reading       |
| 30004            | 3                | Motor load                      | 0 ... 100   | Motor load in % from rated motor power  | UINT16    | reading       |

Holding Register (Device configuration):

| Register-Address | Protocol-Adresse | Name            | Value range    | Description  | Data type | Access rights   |
|------------------|------------------|-----------------|----------------|--|-----------|-----------------|
| 40001            | 0                | Control word 1  | 0 ... 2        | Bit 0 = Reset<br>Bit 1 = Write configuration to EEPROM | UINT16    | write / reading |
| 40002            | 1                | Control word 2  | 0 ... 2        | Bit 0 = RunRight<br>Bit 1 = RunLeft                    | UINT16    | write / reading |
| 40003            | 2                | Ie *)           | 50 ... 500     | Nominal motor current in 1/100 A                       | UINT16    | write / reading |
| 40004            | 3                | Mon *)          | 30 ... 80      | Softstart voltage in % from nominal voltage            | UINT16    | write / reading |
| 40005            | 4                | Ton *)          | 0 ... 100      | Softstart ramp time in 1/10 Sec                        | UINT16    | write / reading |
| 40006            | 5                | Moff *)         | 80 ... 30      | Softstop voltage in % from nominal voltage             | UINT16    | write / reading |
| 40007            | 6                | Toff *)         | 0 ... 100      | Softstop ramp time in 1/10 s                           | UINT16    | write / reading |
| 40008            | 7                | Timeout release | 0 ... 1        | 0 = Disable<br>1 = Enable                              | UINT16    | write / reading |
| 40009            | 8                | Timeout         | 1000 ... 10000 | Timeout value in ms                                    | UINT16    | write / reading |

\*) Parameters can be stored permanently in the EEPROM by setting the Bit "Write configuration to EEPROM"

